

August 4, 2026

Mrs. Alice McCastle
Higher Ground Academy
1381 Marshall Avenue
St. Paul, MN 55104

Emailed to: alicem@hgacademy.org

**Re: Lead Water Sample Results
1381 Marshall Avenue and 1471 Brewster Street, St. Paul MN
Bay West Project No. J260479**

Dear Mrs. McCastle:

Attached are the analytical results for the drinking water samples collected at two buildings located at 1381 Marshall Avenue and 1471 Brewster Street, St. Paul MN. The samples were collected from cold water faucets in the kitchen areas and drinking fountains in the associated buildings. Two samples were collected from each location representing an unflushed water delivery (first draw) and a second after 30 seconds of flushing of the system. A two-part sampling procedure is conducted to determine if a high concentration is identified in the first draw sample, the second sample will identify if the lead is coming from the plumbing behind the fountain/fixture and/or if flushing will assist in reducing lead. Samples were submitted to Pace Analytical Services, LLC, Minneapolis MN for Lead analysis via method Environmental Protection Agency (EPA) 200.8.

Under Minnesota Statutes, 121A.335 Lead in School Drinking Water, schools are required to test for lead, implement a plan and report results. The Minnesota Department of Health (MDH) "Reducing Lead in Drinking Water: A Technical Guidance for Minnesota's School and Child Care Facilities" indicates documented analytical results at or above 5 parts per billion (ppb) or micrograms per liter ($\mu\text{g/L}$) should have lead hazard reduction implemented. The MDH also recommends taking action to minimize lead exposure if lead concentrations are between 2 $\mu\text{g/L}$ and 5 $\mu\text{g/L}$. The analytical results are summarized below and indicate there were no samples with concentration reported above 2 $\mu\text{g/L}$. Future testing for these sample locations should be conducted at a frequency of at least once every five years.

The following table summarizes the analytical results.

1381 Marshall Avenue		
Building Location	Sample Name	Analytical result ($\mu\text{g/L}$)
Kitchen Prep	MBI-Kitchen Prep	1.9
	MBF- Kitchen Prep	0.22J
Cafeteria Drinking Fountain - West	MBI- Caf DF West	0.086J
	MBF- Caf DF West	<0.50
Entrance Drinking Fountain - South	MBI- Entrance DFS	<0.50
	MBF- Entrance DFS	0.074J

1471 Brewster Street		
Building Location	Sample Name	Analytical result (µg/L)
Kitchen Prep	BBI-Kitchen Prep	<0.50
	BBF-Kitchen Prep	<0.50
Entrance Drinking Fountain – West Side	BBI-Entrance DF West	0.16J
	BBF-Entrance DF West	<0.50
Main Hallway Bathroom Drinking Fountain – West Side	BBI-Main Hall Bath DFW	<0.50
	BBF-Main Hall Bath DFW	<0.50
Notes: I = initial and F = after flushing the system J – justified indicating compound was detected between the laboratory minimum detection limit and reporting limit. < - compound was not detected above the laboratory minimum detection limit.		

The chain of custody, sample acknowledgement, and analytical report are presented in the attachment.

Please contact us should have any questions.

Respectfully Submitted,


 Amy Buckley
 Project Manager
 (651) 724-9746
Abuckley@baywest.com


 Bruce Johnson
 Sr. Project Manager
 (651) 724-9755
bjohnson@baywest.com

Attachment: Pace Analytical Report



July 25, 2026

Amy Buckley
Bay West LLC
1450 Energy Park Drive Suite #300
St. Paul, MN 55108

RE: Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Dear Amy Buckley:

Enclosed are the analytical results for sample(s) received by the laboratory on July 13, 2026. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Minneapolis

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads 'Sylvia Hunter'.

Sylvia Hunter
sylvia.hunter@pacelabs.com
1(612)607-1700
Project Manager

Enclosures

cc: Elizabeth Cheney, Bay West
Alan Knudsen, Bay West LLC
Ryan Riley, Bay West
Eddie Weaver, Bay West LLC



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Table of Contents

Sections:

Section 1: Cert Page	3
Section 2: Sample Summary	4
Section 3: Sample Analyte	5
Section 4: Case Narrative	6
Section 5: Results	7
Section 6: Quality Control	19
Section 7: Qualifiers	20
Section 8: QC Cross Reference	21
Section 9: Chain of Custody	22
9.1: Chain of Custody	22

1

2

3

4

5

6

7

8

9



CERTIFICATIONS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Pace Analytical Services, LLC - Minneapolis MN

1700 Elm Street SE, Minneapolis, MN 55414
Alaska Contaminated Sites Certification #: 17-009
Arizona Certification #: AZ0014
Arkansas WW Certification #: 88-0680
Colorado Certification #: MN00064
DoD via A2LA Certification #: 2926.01
Florida Certification #: E87605
Idaho Certification #: MN00064
Indiana Certification #: C-MN-01
ISO/IEC 17025 via A2LA Certification #: 2926.01
Kentucky DW Certification #: 90062
Louisiana DEQ Certification #: AI-03086
Maine Certification #: MN00064
Michigan Certification #: 9909
Minnesota Dept of Ag Approval via Certification #: 027-053-137
Mississippi Certification #: MN00064
Montana Certification #: CERT0092
Nevada Certification #: MN00064
New Jersey Certification #: MN002
North Carolina DW Certification #: 27700
North Dakota Certification via A2LA #: R-036
Ohio DW Certification #: 41244
Oklahoma Certification #: 9507
Oregon Secondary Certification #: MN200001
Puerto Rico Certification #: MN00064
Tennessee Certification #: TN02818
Utah Certification #: MN00064
Virginia Certification #: 460163
West Virginia DEP Certification #: 382
Wisconsin Certification #: 999407970
USDA Permit #: P330-19-00208

Alabama Certification #: 40770
Alaska DW Certification #: MN00064
Arkansas DW Certification #: MN00064
California Certification #: 2929
Connecticut Certification #: PH-0256
EPA Region 8 Tribal Water Systems+Wyoming DW Certification #: via MN 027-053-137
Georgia Certification #: 959
Illinois Certification #: 200011
Iowa Certification #: 368
Kansas Certification #: E-10167
Kentucky WW Certification #: 90062
Louisiana DW Certification #: MN00064
Maryland Certification #: 322
Minnesota Certification #: 027-053-137
Minnesota Petrofund Registration #: 1240
Missouri Certification #: 10100
Nebraska Certification #: NE-OS-18-06
New Hampshire Certification #: 2081
New York Certification #: 11647
North Carolina WW Certification #: 530
North Dakota Certification via MN #: R-036
Ohio VAP Certification (1700) #: CL101
Oregon Primary Certification #: MN300001
Pennsylvania Certification #: 68-00563
South Carolina Certification #: 74003001
Texas Certification #: T104704192
Vermont Certification #: VT-027053137
Washington Certification #: C486
West Virginia DW Certification #: 9952 C
Wyoming UST Certification via A2LA #: 2926.01

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



SAMPLE SUMMARY

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10780216001	MBI-Kitchen Prep	Water	07/13/26 08:15	07/13/26 11:42
10780216002	MBF-Kitchen Prep	Water	07/13/26 08:16	07/13/26 11:42
10780216003	MBI-CafDFWest	Water	07/13/26 08:36	07/13/26 11:42
10780216004	MBF-CafDFWest	Water	07/13/26 08:37	07/13/26 11:42
10780216005	MBI-EntranceDFS	Water	07/13/26 08:52	07/13/26 11:42
10780216006	MBF-Entrance DFS	Water	07/13/26 08:53	07/13/26 11:42
10780216007	BBI-Kitchen Prep	Water	07/13/26 09:25	07/13/26 11:42
10780216008	BBF-Kitchen Prep	Water	07/13/26 09:26	07/13/26 11:42
10780216009	BBI-Entrance DF West	Water	07/13/26 09:32	07/13/26 11:42
10780216010	BBF-Entrance DF West	Water	07/13/26 09:33	07/13/26 11:42
10780216011	BBI-Main Hall Bath DFW	Water	07/13/26 09:42	07/13/26 11:42
10780216012	BBF-Main Hall Bath DFW	Water	07/13/26 09:43	07/13/26 11:42

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



SAMPLE ANALYTE COUNT

Project: J260479 Higher Ground Academy

Pace Project No.: 10780216

W

Lab ID	Sample ID	Method	Analysts	Analytes Reported
10780216001	MBI-Kitchen Prep	EPA 200.8	BK1	1
10780216002	MBF-Kitchen Prep	EPA 200.8	BK1	1
10780216003	MBI-CafDFWest	EPA 200.8	BK1	1
10780216004	MBF-CafDFWest	EPA 200.8	BK1	1
10780216005	MBI-EntranceDFS	EPA 200.8	BK1	1
10780216006	MBF-Entrance DFS	EPA 200.8	BK1	1
10780216007	BBI-Kitchen Prep	EPA 200.8	BK1	1
10780216008	BBF-Kitchen Prep	EPA 200.8	BK1	1
10780216009	BBI-Entrance DF West	EPA 200.8	BK1	1
10780216010	BBF-Entrance DF West	EPA 200.8	BK1	1
10780216011	BBI-Main Hall Bath DFW	EPA 200.8	BK1	1
10780216012	BBF-Main Hall Bath DFW	EPA 200.8	BK1	1

PASI-M = Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



PROJECT NARRATIVE

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Method: EPA 200.8
Description: 200.8 MET ICPMS
Client: Bay West LLC
Date: July 25, 2026

General Information:

12 samples were analyzed for EPA 200.8 by Pace Analytical Services Minneapolis. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Sample Preparation:

The samples were prepared in accordance with EPA 200.8 with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: MBI-Kitchen Prep Lab ID: 10780216001 Collected: 07/13/26 08:15 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Minneapolis									
Lead	1.9	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 17:53	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: MBF-Kitchen Prep Lab ID: 10780216002 Collected: 07/13/26 08:16 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Minneapolis									
Lead	0.22J	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 17:59	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: MBI-CafDFWest Lab ID: 10780216003 Collected: 07/13/26 08:36 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Minneapolis									
Lead	0.086J	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 18:05	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: MBF-CafDFWest Lab ID: 10780216004 Collected: 07/13/26 08:37 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Minneapolis									
Lead	<0.50	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 18:12	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: MBI-EntranceDFS Lab ID: 10780216005 Collected: 07/13/26 08:52 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Minneapolis									
Lead	<0.50	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 18:18	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: MBF-Entrance DFS Lab ID: 10780216006 Collected: 07/13/26 08:53 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Minneapolis									
Lead	0.074J	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 18:31	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: BBI-Kitchen Prep Lab ID: 10780216007 Collected: 07/13/26 09:25 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Minneapolis									
Lead	<0.50	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 18:38	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: BBF-Kitchen Prep Lab ID: 10780216008 Collected: 07/13/26 09:26 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Minneapolis									
Lead	<0.50	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 18:44	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: BBI-Entrance DF West Lab ID: 10780216009 Collected: 07/13/26 09:32 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Minneapolis									
Lead	0.16J	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 18:51	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: BBF-Entrance DF West Lab ID: 10780216010 Collected: 07/13/26 09:33 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Minneapolis									
Lead	<0.50	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 19:05	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: BBI-Main Hall Bath DFW Lab ID: 10780216011 Collected: 07/13/26 09:42 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8									
Pace Analytical Services - Minneapolis									
Lead	<0.50	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 19:18	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



ANALYTICAL RESULTS

Project: J260479 Higher Ground Academy
Pace Project No.: 10780216

Sample: BBF-Main Hall Bath DFW Lab ID: 10780216012 Collected: 07/13/26 09:43 Received: 07/13/26 11:42 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS									
Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Minneapolis									
Lead	<0.50	ug/L	0.50	0.060	1	07/21/26 06:16	07/23/26 19:24	7439-92-1	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: J260479 Higher Ground Academy

Pace Project No.: 10780216

QC Batch 1076217

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET

Laboratory: Pace Analytical Services - Minneapolis

Associated Lab Samples: 10780216001, 10780216002, 10780216003, 10780216004, 10780216005, 10780216006, 10780216007, 10780216008, 10780216009, 10780216010, 10780216011, 10780216012

METHOD BLANK: 5592522

Matrix: Water

Associated Lab Samples: 10780216001, 10780216002, 10780216003, 10780216004, 10780216005, 10780216006, 10780216007, 10780216008, 10780216009, 10780216010, 10780216011, 10780216012

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	<0.50	0.50	0.060	07/23/26 17:14	

LABORATORY CONTROL SAMPLE: 5592523

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	99.6	100	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5592524

5592525

Parameter	Units	10780485001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qualifiers
Lead	ug/L	0.071J	100	100	102	98.1	102	98	70-130	4	20	

MATRIX SPIKE SAMPLE: 5592526

Parameter	Units	10780216010 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<0.50	100	99.8	100	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



QUALIFIERS

Project: J260479 Higher Ground Academy

Pace Project No.: 10780216

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: J260479 Higher Ground Academy

Pace Project No.: 10780216

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10780216001	MBI-Kitchen Prep	EPA 200.8	1076217	EPA 200.8	1076782
10780216002	MBF-Kitchen Prep	EPA 200.8	1076217	EPA 200.8	1076782
10780216003	MBI-CafDFWest	EPA 200.8	1076217	EPA 200.8	1076782
10780216004	MBF-CafDFWest	EPA 200.8	1076217	EPA 200.8	1076782
10780216005	MBI-EntranceDFS	EPA 200.8	1076217	EPA 200.8	1076782
10780216006	MBF-Entrance DFS	EPA 200.8	1076217	EPA 200.8	1076782
10780216007	BBI-Kitchen Prep	EPA 200.8	1076217	EPA 200.8	1076782
10780216008	BBF-Kitchen Prep	EPA 200.8	1076217	EPA 200.8	1076782
10780216009	BBI-Entrance DF West	EPA 200.8	1076217	EPA 200.8	1076782
10780216010	BBF-Entrance DF West	EPA 200.8	1076217	EPA 200.8	1076782
10780216011	BBI-Main Hall Bath DFW	EPA 200.8	1076217	EPA 200.8	1076782
10780216012	BBF-Main Hall Bath DFW	EPA 200.8	1076217	EPA 200.8	1076782



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 07/25/2026 08:57 PM

ENV-FRM-MIN4-0150 v21 Sample Condition Upon Receipt

Person Examining & Date:

MRCF 7/13/26

PROJECT #:

MO#: 10780216

PH: SH1

Due Date: 07/27/26

CLIENT: BW-BAY WEST

Client Name:

Bay West

Custody Seal Present: ☐ YES ☒ NOSeals Intact: ☐ YES ☒ NO

Tracking Number:

Courier: ☒ Client☐ Commercial☐ Fedex☐ Pace Courier/Field☐ Speedee☐ UPS☐ USPS☐ See Exceptions form ENV-FRM-MIN4-0142

Packing Material:

☐ Bubble Bags☒ Bubble Wrap☐ None☐ Other:Biological Tissue Frozen: ☐ YES ☒ NO

Thermometer:

☐ T1 (0461)☐ T2 (0431)☐ T3 (0459)☐ T4 (0402)Type of Ice: ☐ Blue☐ Dry☐ Wet☐ Melted☒ None☐ T5 (0187)☐ T6 (0396)☐ T7 (0377)☐ T8 (0775)☒ T9 (0428)☐ 01339252 (0710)Temp Blank: ☒ YES ☐ NONOTE: Temp should be $\leq 6^{\circ}\text{C}$, but above freezing.Read Temp w/Temp Blank: 23.4°C Correction Factor: -0.5°C Average Corrected Temp w/Temp Blank Only: 9.1°C Did Samples Originate from one of the following states (check maps): ☐ YES ☐ NOWere All Containers Sealed? ☒ YES ☐ NOTemp Taken: ☐ YES ☐ NO ☐ N/ACorrected Temp w/Temp Blank: 22.9°C ☐ See Exceptions form ENV-FRM-MIN4-0142.☐ 1 ContainerUSDA Regulated Soil: ☒ N/A - Water Sample/Other (describe):Did Samples Originate from one of the following states (check maps): ☐ YES ☐ NOAre samples from a foreign source (international, including Hawaii and Puerto Rico): ☐ YES ☐ NO

NOTE: If YES to either question, fill out a Regulated Soil Checklist (ENV-FRM-MIN4-0150) and include with SCUR/COC paperwork.

LOCATION (check one):	☐ DULUTH	☒ MINNEAPOLIS	☐ VIRGINIA	YES	NO	N/A	COMMENTS(S)
Chain of Custody Present and Filled Out? (i.e., Analysis/ID/Date/Time)	☒	☒	☐	☒	☐	☐	1.
Chain of Custody Relinquished?	☒	☒	☐	☒	☐	☐	2.
Sampler Name and/or Signature on COC?	☒	☒	☐	☒	☐	☐	3.
Samples Arrived within Hold Time?	☒	☒	☐	☒	☐	☐	4.
NOTE: < 24 hrs if lab filter is requested for Dissolved LL-Mercury by 1631E.	☒	☒	☐	☒	☐	☐	If Fecal: ☐ < 8 hrs ☐ > 8 hr but < 24 hrs ☐ > 24 hr
Short Hold Time Analysis (< 72 hr)?	☒	☒	☐	☒	☐	☐	5. ☐ BOD / cBOD ☐ Fecal coliform ☐ Hex Chrom
	☒	☒	☐	☒	☐	☐	☐ HPC ☐ Nitrate ☐ Nitrite ☐ Ortho Phos
	☒	☒	☐	☒	☐	☐	☐ Total coliform/E. coli ☐ Turbidity ☐ Other:
Rush Turn Around Time Requested?	☒	☒	☐	☒	☐	☐	6. ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day ☐ 5 Day
	☒	☒	☐	☒	☐	☐	Due Date: _____
Sufficient Sample Volume? (If NO, list approximate volume in section 7.)	☒	☒	☐	☒	☐	☐	7.
Correct Containers Used?	☒	☒	☐	☒	☐	☐	8. 1-12: 1BP 3V
- Pace Containers Used?	☒	☒	☐	☒	☐	☐	
Containers Intact?	☒	☒	☐	☒	☐	☐	9.
Field Filtered Volume Received for Dissolved Tests?	☒	☒	☐	☒	☐	☐	10.
ID/Date/Time Match? (If NO, fill out section 11.)	☒	☒	☐	☒	☐	☐	11. ☐ See Exceptions form ENV-FRM-MIN4-0142
Matrix: ☐ Oil ☐ Soil ☒ Water ☐ Other	☒	☒	☐	☒	☐	☐	12.
All containers needing acid/base preservation have been checked?	☒	☒	☐	☒	☐	☐	
Sample #: 1-12: 11	☒ HNO3	☐ H2SO4	☐ NaOH	☐	☐	☐	
pH Paper Lot #: 229725	☐ Residual Chlorine	☒ 0-6 Strip	☐ 0-14 Strip	☐	☐	☐	
Preserved containers in compliance with EPA recommendations? (HNO3, H2SO4, < 2 pH, NaOH > 9 Sulfide, NaOH > 10 Cyanide)	☒	☒	☐	☒	☐	☐	☐ See Exceptions form ENV-FRM-MIN4-0142
EXCEPTIONS (water only): VOA, Coliform, TOC/DOC, Oil & Grease, Phenols, DRO/RO15, Dioxins, and PFAS	☒	☒	☐	☒	☐	☐	
Extra labels present on soil VOA or W/DRO containers? (soil only)	☒	☒	☐	☒	☐	☐	13.
Headspace in Methyl Mercury Container?	☒	☒	☐	☒	☐	☐	14.
Headspace in VOA Vials (greater than 6mm)?	☒	☒	☐	☒	☐	☐	☐ See Exceptions form ENV-FRM-MIN4-0140
Trip Blanks Present?	☒	☒	☐	☒	☐	☐	15.
Trip Blank Custody Seals Present?	☒	☒	☐	☒	☐	☐	Pace Trip Blank Lot # (if purchased): _____

CLIENT NOTIFICATION / RESOLUTION:

Labeled By: MRCF

Unit: 2

Person Contacted & Date/Time:

PM Review & Date:

NOTE: When there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEQ Certification Office.

7/14/26

Qualtrax ID: 52742

Effective Date: 10/01/25

Pace® Analytical Services, LLC (PAS)

Page 1 of 1